SRI CHOWDESHWARI BOREWELLS

5th Cross, Maruthi Layout, Dasarahalli Main Road, H.A. Farm Post,
Bengaluru - 560 024. Mob. : 9845370182, 9535764954

Kaveriamma layout main road (near Railway station)

To,
Assistant Executive Engineer
yelahanka Sub division.
BDMP. Bangalore-64

No. ~~~~~

Date : 30/04/2019

Sl. No.	PARTICULARS	Rft	WATER YEILD	REMARKS
1.	Size of the Borewell	165mmΦ		
2.	Total Depth of the Borewell	980 feet		
3.	MS Casing Erected	75 feet		
4.	1st Water Source at the Depth	four feet	-	
5.	2nd Water Source of the Depth	Five feet	-	
6.	3rd Water Source of the Depth	820 feet	-	
7.	4th Water Source of the Depth	960 feet	-	
8.	If any Silt, Boulders at the Depth	silt	-	
9.	Nature of Water	NO	-	
10.	Motor Pump to be used	NO	-	Fail
11.	Any other Remarks	NO	-	
12.	Total Yield of the Borewell	NO	NO	

AE-2

Thanking You

Received AE-02

Yours Faithfully
For **CHOWDESHWARI BOREWELLS**

Received AE-02

Smt. Kavitha Singh

SRI CHOWDESHWARI BOREWELLS

5th Cross, Maruthi Layout, Dasarahalli Main Road, H.A. Farm Post,
Bengaluru - 560 024. Mob. : 9845370182, 9535764954

Marahalli (Next to Gangamma Temple)

To,
Assistant Executive Engineer
Yelahanka Sub division.
BBMP. Bangalore-64

No.

Date : 25/04/2019

Sl. No.	PARTICULARS	Rft	WATER YEILD	REMARKS
1.	Size of the Borewell	165 mm ϕ		
2.	Total Depth of the Borewell	980 feet		
3.	MS Casing Erected	75 feet		
4.	1st Water Source at the Depth	650 feet	1"	
5.	2nd Water Source of the Depth	720 feet	1½"	
6.	3rd Water Source of the Depth	800 feet	1½"	
7.	4th Water Source of the Depth	950 feet	-	
8.	If any Silt, Boulders at the Depth	NO	NO	
9.	Nature of Water	Salt	-	
10.	Motor Pump to be used	yes	-	Pass
11.	Any other Remarks	NO	-	
12.	Total Yield of the Borewell	960 feet	2½"	

AE-II

Thanking You

AE-02

Yours Faithfully
For **CHOWDESHWARI BOREWELLS**

AE-II

Smt. Kavitha Singh

SRI CHOWDESHWARI BOREWELLS

5th Cross, Maruthi Layout, Dasarahalli Main Road, H.A. Farm Post,
Bengaluru - 560 024. Mob. : 9845370182, 9535764954

Konchenahalli Near Hanuman Temple

To,
Assistant Executive Engineer
yelahanka Sub division.
BBMP. Bangalore-64

No.

Date : 18/04/2019

Sl. No.	PARTICULARS	Rft	WATER YEILD	REMARKS
1.	Size of the Borewell	165 ಅಡಿಗಳಲ್ಲಿ		
2.	Total Depth of the Borewell	1000 feet		
3.	MS Casing Erected	90 feet		
4.	1st Water Source at the Depth	620 feet	1"	
5.	2nd Water Source of the Depth	840 feet	1"	
6.	3rd Water Source of the Depth	900 feet	1½"	
7.	4th Water Source of the Depth	960 feet	-	
8.	If any Silt, Boulders at the Depth	ND	ND	
9.	Nature of Water	Sweet	-	
10.	Motor Pump to be used	Yes	-	Pass
11.	Any other Remarks	ND	-	
12.	Total Yield of the Borewell	980 feet	2"	

Thanking You

AE-02

Yours Faithfully
For **CHOWDESHWARI BOREWELLS**

AE-02

Smt. Rathna

SRI CHOWDESHWARI BOREWELLS

5th Cross, Maruthi Layout, Dasarahalli Main Road, H.A. Farm Post,
Bengaluru - 560 024. Mob. : 9845370182, 9535764954

Nayesraballi

To,
Assistant Executive Engineer
yelahanka Sub division.
BBMP Bangalore-64

No.

Date : 11/04/2019

Sl. No.	PARTICULARS	Rft	WATER YEILD	REMARKS
1.	Size of the Borewell	165 mm ϕ		
2.	Total Depth of the Borewell	960 feet		
3.	MS Casing Erected	80 feet		
4.	1st Water Source at the Depth	650 feet	1"	
5.	2nd Water Source of the Depth	720 feet	1"	
6.	3rd Water Source of the Depth	800 feet	1 1/2"	
7.	4th Water Source of the Depth	920 feet	-	
8.	If any Silt, Boulders at the Depth	NO	NO	
9.	Nature of Water	Sweet	-	
10.	Motor Pump to be used	yes	-	Pass
11.	Any other Remarks	NO	-	
12.	Total Yield of the Borewell	960 feet	2"	

Thanking You

Yours Faithfully
For **CHOWDESHWARI BOREWELLS**

SRI CHOWDESHWARI BOREWELLS

5th Cross, Maruthi Layout, Dasarahalli Main Road, H.A. Farm Post,
Bengaluru - 560 024. Mob. : 9845370182, 9535764954

Karnakshamma Layout (opposite to Vijayajyothi School)

To,
Assistant Executive Engineer
Yelahanka Sub division.
BBMP. Bangalore-64

No.

Date : 08/04/2019

Sl. No.	PARTICULARS	Rft	WATER YEILD	REMARKS
1.	Size of the Borewell	165 mm ϕ		
2.	Total Depth of the Borewell	1000 feet		
3.	MS Casing Erected	80 feet		
4.	1st Water Source at the Depth	680 feet	-	
5.	2nd Water Source of the Depth	750 feet	-	
6.	3rd Water Source of the Depth	800 feet	-	
7.	4th Water Source of the Depth	940 feet	-	
8.	If any Silt, Boulders at the Depth	Silt	-	
9.	Nature of Water	ND	-	
10.	Motor Pump to be used	NO	-	Fail
11.	Any other Remarks	ND	-	
12.	Total Yield of the Borewell	ND	ND	

Thanking You

Yours Faithfully
For **CHOWDESHWARI BOREWELLS**

Smt. Kavitha Singh

SRI CHOWDESHWARI BOREWELLS

5th Cross, Maruthi Layout, Dasarahalli Main Road, H.A. Farm Post,
Bengaluru - 560 024. Mob. : 9845370182, 9535764954

Kondappa Layout 27th Cross

To,
Assistant Executive Engineer
yelahanka Sub division
BBMP. Bangalore-64

No.

Date : 03/04/2019

Sl. No.	PARTICULARS	Rft	WATER YEILD	REMARKS
1.	Size of the Borewell	165 mm		
2.	Total Depth of the Borewell	980 feet		
3.	MS Casing Erected	75 feet		
4.	1st Water Source at the Depth	650 feet	1"	
5.	2nd Water Source of the Depth	720 feet	1½"	
6.	3rd Water Source of the Depth	790 feet	1½"	
7.	4th Water Source of the Depth	950 feet	-	
8.	If any Silt, Boulders at the Depth	NO	NO	
9.	Nature of Water	Sweet	-	
10.	Motor Pump to be used	YES	-	Pass
11.	Any other Remarks	NO	-	
12.	Total Yield of the Borewell	960 feet	2"	

Thanking You

AE

Yours Faithfully
For **CHOWDESHWARI BOREWELLS**